

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

12. ACCOUNTING AND APPROPRIATION DATA (If required)

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.			
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).			
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:			
D. OTHER (Specify type of modification and authority)			
E. IMPORTANT: Contractor _____ is not, _____ is required to sign this document and return it to the issuing office.			
<p>14. DESCRIPTION OF AMENDMENT/MODIFICATION</p> <p>SEE CONTINUATION PAGE</p> <p>Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.</p>			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____		By _____	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

This Amendment No. 01 is issued to the above referenced solicitation to replace pages with those that have corrections and/or changes made to them as identified by the black lines in the right margin. Please replace the following pages with those currently in the solicitation package.

Remove Pages

Solicitation Conditions, Page 10
Deficiency Report, Page C-19

Insert Pages/Sections/Drawings

Solicitation Conditions, Page 10
Deficiency Report, Page C-19

Updated drawing can be mailed upon request or picked up at the pre-bid/site visit meeting.

NOTE:

The due date and time for receipt of offers remains March 9, 2006, 1:00 PM.

Attachments

Solicitation Conditions, 1 page
Deficiency Report, 1 page

(a) Failure to furnish an Offer Guarantee in the required form and amount, with and as a part of the proposal, will be cause for rejection of the proposal.

(b) The offeror shall furnish an Offer Guarantee of not less than 20% of the proposed price in the form of a firm commitment consisting of a Bid Bond, Certified Check, Cashier's Check, Irrevocable Letter of Credit, or Postal Money Order made payable to the Architect of the Capitol, or, under Treasury Department Regulations, certain bonds or notes of the United States. The Contracting Officer will return Offer Guarantees, other than Bid Bonds, (1) to unsuccessful offerors as soon as practicable after evaluation of the proposals; and (2) to the successful offeror upon execution of contractual documents and bonds (including any necessary coinsurance or reinsurance agreements), as required by the offer as accepted.

(End of provision)

(a) It is strongly recommended that all prospective offerors visit the site where the work is to be performed, compare the work requirements with existing conditions, verify dimensions, if necessary, and fully inform themselves regarding the nature and scope of the proposed work and the conditions under which it will be conducted. Offerors shall also inform themselves regarding other work, if any, being done or to be done by or for the United States government, the District of Columbia government and utility companies, by contract or otherwise, where such work may affect or be affected by the operations under the contract. Failure to take these precautions will in no way relieve the successful offeror from his obligation to furnish all materials, services, labor, and any other requirements necessary to complete the work satisfactorily under the conditions established by the contract documents and without additional expense to the Government.

(b) **A pre-proposal meeting will be conducted at the Dirksen Senate Office Building, Room SDG45, Washington, D.C. for all prospective offerors on February 15, 2005 at 10:00 A.M., local time.**

(c) **The Architect will conduct one field inspection of the work immediately following the pre-proposal meeting. Those intending to participate shall meet at the address above. Information concerning the meeting may be obtained by telephoning Mr. Mike Edwards at (202) 228-5002.**

(d) Offerors are encouraged to submit all questions in writing at least five (5) working days prior to the conference. Questions will be considered at any time prior to or during the conference; however, offerors will be asked to confirm verbal questions in writing. Subsequent to the conference, an amendment to the solicitation containing an abstract of the questions and answers, and a list of attendees, will be disseminated.

HART SPRINKLER SYSTEM DEFICIENCIES				
Cmnt #	Floor	Room/Location	# of Sprinklers Required	Deficiency
8-18	Eighth	Office H833		Sprinkler coverage does not correspond with partition layout.
8-19	Eighth	Office H830		Sprinkler coverage does not correspond with partition layout.
8-20	Eighth	Office H828		Sprinkler coverage does not correspond with partition layout.
8-21	Eighth	Office 838		Sprinkler coverage does not correspond with partition layout.
8-22	Eighth	Atrium Ceiling		None provided in Atrium.
8-23	Eighth	Elevator Mechanical Room H8AS		None provided.
8-24	Eighth	Elevator Mechanical Room H8DS		None provided.
8-25	Eighth	Telephone Closet H8AT		None provided.
8-26	Eighth	Electric Closet H8AE		None provided.
8-27	Eighth	Telephone Closet H8DT		None provided.
8-28	Eighth	Electric Closet H8DE		None provided.
8-29	Eighth	Electric Closet H8EE		None provided.
8-30	Eighth	Telephone Closet H8ET		None provided.
8-32	Eighth	Electric Closet H8FE		None provided.
8-32	Eighth	Telephone Closet H8FT		None provided.